

The Peloton
Special EBLast - 10.26.17

4:00 AM Fire Alarm Incident - Explanation

Today (Thursday, October 26, 2017) at about 4:00 am, the Bldg C (3701 Arapahoe) central fire alarms sounded. Management was contacted by Meridian Central Security immediately and informed that the Fire Department had been dispatched to the property, and our Building Engineer arrived at the property shortly thereafter.

We wanted to share with you what we have learned about this event.

There was no fire in Bldg C or anywhere on the property. The central fire alarms sounded due to the Bldg C panel indicating a water flow problem in the sprinkler lines. This may have been just an air bubble in the system. The panel was reset by the Fire Department once the water flow problem cleared. The Fire Department departed the property after the panel reset and the alarms were shut off. Management will receive a report from the Fire Department for our files, and if there is any other important information stemming from that report once received that should be shared with the community, we will provide it to you.